

FL # FL9692 Application Type New Code Version 2004 Application Status Approved

Comments Archived Product Manufacturer Mesker Door, Inc. Address/Phone/Email 3440 Stanwood Blvd.

Huntsville, AL 35811
(256) 851-6670

rickw@rwldgconsultants.com Authorized Signature Stephen Frates

rickw@rwldgconsultants.com Technical Representative Address/Phone/Email Quality Assurance Representative Address/Phone/Email Category Exterior Doors Subcategory Swinging Exterior Door Assemblies Compliance Method Evaluation Report from a Florida Registered Architect or a Licensed Florida Professional Engineer

Evaluation Report - Hardcopy Received

Florida Engineer or Architect Name Wendell W. Haney
who developed the Evaluation Report

Florida License

PE-54158

Quality Assurance Entity

National Accreditation and Management Institute

Validated By

L.F. Schmidt, P.E.

Referenced Standard and Year (of Standard)

<u>Standard</u>	<u>Year</u>
Accepted Engineering Practice	2004
TAS 201, 202, 203	1994
Equivalence of Product Standards Certified By	

Sections from the Code

Product Approval Method Method 1 Option D Date Submitted 09/15/2007 Date Validated 12/27/2007

Date Pending FBC Approval 12/30/2007

Date Approved 12/31/2007

Summary of Products

FL #	Model, Number or Name	Description
------	-----------------------	-------------

9692.1	a. "H" and "HURRICANE" Series Commercial Steel Door	Up to a 3'0 x 7'0 Outswing 16 ga. Opaque Commercial Steel Door in a 16 ga. Hollow Metal Frame - Double Configuration (X)
<p>Limits of Use Approved for use in HVHZ: Yes Approved for use outside HVHZ: Yes Impact Resistant: Yes Design Pressure: N/A Other: Note - This product meets the water requirements of the "HVHZ" up to a positive DP of 50 PSF. For installations where the positive DP > 50 PSF, this product does not meet the water requirements for the High Velocity Hurricane Zone (HVHZ) and the product shall be installed only in non-habitable areas or at habitable locations protected by an overhang or canopy such that the angle between the edge of canopy or overhang to sill is less than 45 degrees. See INST 9692.1 for Design Pressure Ratings.</p>		