

Certificate of Compliance

Certificate Number: 20101025-R12339
Report Reference: R12339
Issue Date: 2010 October 25

Page 1 of 2



Issued to: Mesker Door Inc.

3440 Stanwood Blvd.
Huntsville, AL 35811


*This is to certify that
representative samples of* **Fire Door Frames**
See Addendum Page

Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 10B - Fire Tests of Door Assemblies
UL 10C - Standard for Positive Pressure Fire Tests of Door Assemblies
NFPA 252 - Standard for Fire Tests of Door Assemblies

Additional Information: See UL On-Line Certification Directory at www.UL.com for additional information.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle,  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/customercontact>

Certificate of Compliance

Certificate Number 20101025-R12337

Report Reference R12337

Issue Date 2010 October 25

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

4'0" x 8'0" single doors with 20, 18, 16 or 14 gauge face skins rated up to and including 3 hr.

4'0" x 10'0" single with 18, 16, or 14 gauge face skins rated up to and including 3 hr. 8'0" x 8'0" pairs

of doors with 20, 18, 16 or 14 gauge face skins rated up to and including 3 hr. Listed single point locks,

fire exit hardware and auxiliary hardware may be used. Astragal required for 3 hr. pairs.

Product can bear a "S" Mark to demonstrate compliance with NFPA 105

William R. Carney

Director, North American Certification Programs

Underwriters Laboratories Inc.

Any indication and designation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a list of UL Customer Service Representatives at <http://www.ul.com/global/en/pages/usa/products/certification>.