

Certificate of Compliance

Certificate Number 20101025-R12337
Report Reference R12337
Issue Date 2010 October 25

Page 1 of 2



Issued to: Mesker Door Inc.

3440 Stanwood Blvd.
Huntsville, AL 35811

*This is to certify that
representative samples of*

Swinging Type Fire Doors
N-Series Door and D-Series Door

Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety:

UL 10B - Fire Tests of Door Assemblies
UL 10C - Standard for Positive Pressure Fire Tests of Door Assemblies
NFPA 252 - Standard for Fire Tests of Door Assemblies

Additional Information:

See UL On-Line Certification Directory at www.UL.com for additional information

Only those products bearing the UL Listing Mark for Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate Canadian requirements.

The UL Listing Mark for Canada includes: the UL Mark for Canada:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier in English, French, or English/French) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney

Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>

Certificate of Compliance

Certificate Number 20101025-R12337

Report Reference R12337

Issue Date 2010 October 25

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

4'0" x 8'0" single doors with 20, 18, 16 or 14 gauge face skins rated up to and including 3 hr.

4'0" x 10'0" single with 18, 16, or 14 gauge face skins rated up to and including 3 hr.

8'0" x 8'0" pairs of doors with 20, 18, 16 or 14 gauge face skins rated up to and including 3 hr. Listed single point locks, fire exit hardware and auxiliary hardware may be used. Astragal required for 3 hr. pairs. Product can bear a "S" Mark to demonstrate compliance with NFPA 105

24" x 24" louvers 48" x 48 metal kick plates may be used on bottom of door leaf. May use 100² in. of wired glass on doors rated up to 1-1/2 hr. or 100² in. of Firelite glass for door rated up to and including 3 hr.

William R. Carney

Director, North American Certification Programs

Helena Y. Wolf

Director, Global Market Access Operations

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>