

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 121300 - R12337
ISSUE DATE: December 13, 2000

Page 2 of

24" x 24" louvers 48" x 48" metal kick plates may be used on bottom of door leaf. May use 100² in. of wired glass on doors rated up to 1-1/2 hr. or 100² in. of Firelite glass for door rated up to and including 3 hr.

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Engineer: 
MARK CHRISTENSEN
Underwriters Laboratories Inc.

Review Engineer:
HOWARD J. GRUSZYNSKI
Underwriters Laboratories Inc.