



## CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 121300 - R12337

ISSUE DATE: December 13, 2000 Page 1 of 1

Issued to: Mesker Door Inc.  
3440 Stanwood Blvd.  
Huntsville, AL 35811

Report Reference: R12337


This is to Certify that  
representative samples of: Swinging Type Fire Doors - Models Swingdor and Diamondor Polystyrene,  
Honeycomb, and Fiberboard core doors

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)  
indicated on this Certificate.

Standard(s) for Safety: UL 10C - Standard for Positive Pressure Fire Tests of Door Assemblies  
UBC 7-2 (1997) - Part I - Fire Tests of Door Assemblies  
UBC 7-2 (1997) - Part II (air leakage)\* - Fire Tests of Door Assemblies  
UL 10B - Fire Tests of Door Assemblies  
NFPA 252 - Standard for Fire Tests of Door Assemblies  
\*an "S" on the product denotes a product which is additionally Classified in accordance with  
UBC 7-2, (1997) Part II for air leakage


Additional Information: 4'0" x 8'0" single doors with 20, 18, 16 or 14 gauge face skins rated up to and  
including 3 hr. 4'0" x 10'0" singles with 18, 16, or 14 gauge face skins rated  
up to and including 3 hr. 8'0" x 8'0" pairs of doors with 20, 18, 16 or 14  
gauge face skins rated up to and including 3 hr. Listed single point locks,  
fire exit hardware and auxiliary hardware may be used. Astragal required  
for 3 hr. pairs.

Only those products bearing the UL Classification Marking should be considered as being  
covered by UL's Classification and Follow-Up Service.

The UL Classification Marking includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number  
(may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product  
category name (product identity) as indicated in the appropriate UL Directory.

### **LOOK FOR THE UL CLASSIFICATION MARKING ON THE PRODUCT**

Engineer:   
MARK CHRISTENSEN  
Underwriters Laboratories Inc.

Review Engineer:   
HOWARD J. GRUSZYNSKI  
Underwriters Laboratories Inc.